



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/12/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-26	Slew not taking place	Drive tripped.Reset done	01:13:00 03:30:00	01:28:00 03:50:00	
2	OHP	TBS on CO-7A	LT not moving.	Right luff limit tied and tested okay	01:55:00	02:10:00	
3	OHP	CO-25	Reported tripped	OLR acted.Reset done	04:20:00	04:30:00	
4	OHP	BRC on CO-32	LT not taking place	Drive tripped.Reset done	05:00:00	05:20:00	
5	OHP	CO-111	Reported tripped	OLR acted.Chute jamming found.Reset done	05:00:00	05:10:00	Informed to operation
6	OHP	CO-85	Reported tripped	OLR acted.Reset done	05:20:00	05:25:00	
7	OHP	CO-37A	BRS not healthy	Checked and found relay output not coming.Changed to second contact and tested okay	23:25:00	00:50:00	
8	OHP	CO-20	ZSS acting pending from B-shift	Checked and found motor gearbox rotating but belt not rotating.	22:00:00	22:25:00	Informed to operation
9	CHP	CC 109	ZSS acting	Material stuck in cage.Made free and tested okay	02:00:00	02:10:00	
10	CHP	CC-33 R-1	B/C not running	ZSS cage stuck.Made free and tested okay	02:40:00	03:00:00	
11	CHP	Cc 131	Reported tripped	OLR acted.Reset done	04:10:00 05:40:00	04:15:00 05:45:00	