



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/08/2025

Area: WT

Equipment	Job
OP 4	Panel and motor side ppm done
CP 4	Panel side ppm done
OT 5	3*1.5 Ar control cable laid from LS1 to LS2 ,connected and kept in circuit
OC 1A	Pull cards checking done , Right side switch and Lift side software cable damaged .
OP 1,4,6,7 and CP1	After rake maintenance done