



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/01/2026

Area: WT

| Equipment | Job |
|------------------|--|
| OP 6 | Section isolators maintenance done,2 nos (col no:84 and 91) |
| OP 5 | Section Isolators maintenance done ,5nos (col no:67,72,79,87,93) |
| OP 2 ,3, 5 and 6 | After rake maintenance done |
| MIS | Bed drain pumps inspection done both Tipplers and status informed to WMD |
| MIS | 75W sample LEDs installed one @ OAF level and one @ LC 10A entrance area |