



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/05/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 30	mechanical brs acted JOD	reset it done	20:45:00	20:55:00	
2	OHP	co 26	olr acted	reset it done	21:45:00	21:59:00	
3	CHP	BRC 30	b/c olr acted	reset it done	21:30:00	21:45:00	
4	CHP	CC 36 SCR1	ZSS problem,proximity switch malfunctioning	proximity switch replaced	14:20:00	14:40:00	
5	CHP	CC 32 SCR 5	LT not taking place,drive trips in OL	reset it done	15:30:00	15:40:00	
6	CHP	CC 108	healthy stop after 3 sec running,found that cc 219 running bit fbk missing form AB PLC TO SIEMENS	PROGRAM modified in siemens, 3s off delay timer kept for AB plc to SIEMENS	21:00:00	21:45:00	
7	CHP	cc 44	mpd trips in oL	reset it done	21:20:00	21:30:00	
8	IOSA	WOBR old	LT not taking palce, OT acted	released OT	20:15:00	20:30:00	