



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/01/2026

Area: CHP

Equipment	Job
CC-102,103,26A,27A,25,26,27	Belt sway switches checking is under progress
CC-55	Motor and panel ppm done
CC-57	20 no"s Belt sway switches checking done and 17no's made ok upto Head end. Cable to be laid from Head End to CJB
SCR-7	Cable laying completed. Dressing is in progress. Connections are in progress. Profibus cable laying done