



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 20 LEFT LUFF UP	LIMIT SWITCH PROBLEM	ADJUSTED	14:30:00	14:45:00	LIMIT SWITCH TO BE REPLACED
2	OHP	BRC ON CO 30 B/C NOT RIUNNING	EMERGENCY STOP NOT RELEASED	RELEASED THEN OK	21:35:00	21:45:00	
3	CHP	CC 131	OLR ACTED	RESET	15:35:00 20:05:00	15:40:00 20:20:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	19:20:00	19:25:00	
5	CHP	CC 114	OLR ACTED	RESET	19:15:00	19:25:00	
6	CHP	SCR 6 ON CC 39	LT DRIVE TRIPPED	RESET	16:05:00	16:15:00	
7	CHP	CC 28 POSITION NOT COMING	FUSE BLOWN	REPLACED	18:45:00	18:55:00	
8	IOSA	OC 37A	BRS NOT RESETTING	SENSOR ADJUSTMENT DONE THEN OK	20:40:00	20:50:00	