



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/07/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	14:30:00	14:35:00	
2	OHP	CO 29	OLR ACTED	RESET	16:50:00	17:00:00	
3	OHP	CO 63(B)DRIVE	OLR ACTED	RESET	19:30:00	19:45:00	DUE TO BELT OFF CENTERING AND SMOKE COME FROM GEAR BOX
4	OHP	CO 66	OLR ACTED	RESET	19:30:00	19:40:00	
5	OHP	CO 35	OLR ACTED	RESET	20:40:00	20:50:00	
6	OHP	CO-33M BRC-4	Reported LT not taking place	Checked and found Drive tripped.Reset done and tested okay	21:20:00	21:30:00	
7	CHP	CC 201	OLR ACTED	RESET	14:30:00	14:40:00	
8	CHP	CC 203	OLR ACTED	RESET	14:30:00	14:40:00	
9	CHP	CC202	PC AND OLR ACTED	OLR RESET AND PC RELEASED	14:30:00	14:45:00	
10	CHP	CC 34 -SCR 2	SLEW NOT TAKING PLACE DRIVE TRIP	RESET THAN OK	15:20:00	15:35:00	
11	CHP	CC 31 S-3	SLEW NOT TAKING PLACE MATERIAL JAMMING	INFORMED TO OPERATION	15:30:00	15:40:00	
12	CHP	CC 31	OLR ACTED	RESET	19:50:00	19:55:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/07/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 104 SCR-9	TUL C/S ACTED	JAMMING CLEANING THAN OK	20:44:00	20:50:00	
14	CHP	CC 54	OLR ACTED (4TIMES)	RESET	15:15:00	19:05:00	
15	CHP	CC113A	OLR ACTED	RESET	18:10:00	18:20:00	
16	CHP	CC 117	OLR ACTED	RESET	19:00:00	19:10:00	
17	CHP	CC 51	OLR ACTED	RESET	21:35:00	21:40:00	
18	CHP	CC-104 SCR 9	Reported luff up not taking place	Checked and found rotary cam switch limit acted. Bypassed at I/o rack and luff up tested okay	18:00:00	19:15:00	Rotary cam switch to be adjusted and to be kept in line
19	WT	CC 2 (C) DRIVE	OLR ACTED	RESET	15:30:00 21:15:00	15:40:00 21:20:00	