



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	03:00:00	03:10:00	
2	OHP	wobr on CO 26	slew not working,drive triped	reset	04:00:00	04:15:00	
3	OHP	BRC on Co 8A	b/w not running,zss acted	probe adjusted	02:30:00	02:55:00	
4	OHP	CO 25	OLr acted	reset	04:30:00	05:40:00	3 times
5	CHP	CC 125	olr acted	reset	04:03:00	04:07:00	
6	CHP	CC 38 SCR 6	Lt not working,track jamming	informed operation	04:02:00	04:15:00	
7	CHP	cc 32 SCR5	LT not working,wrong complaint	all ok	05:30:00	05:39:00	
8	CHP	CC 53	MPCp tripped due to overload	made it on,informed operation	04:55:00	04:59:00	
9	CHP	CC 51	mpd tripped	reset	02:45:00	02:50:00	
10	CHP	CC 52	mod tripped	reset	03:00:00	03:05:00	
11	CHP	VS 3	tripped due to overload	reset	05:00:00	05:10:00	
12	WT	OT 5	clamping not working	given in manual and then auto	04:10:00	04:20:00	