



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	21:00:00	21:10:00	
2	OHP	BRC ON CO 34 LT	PCRD CONTACTOR GOT STUCK	MADE IT FREE	16:30:00	17:00:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	17:50:00	21:30:00	6 TIMES