



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 09/08/2025

Area: IOSA

Equipment	Job
WOBR- L and T	TRIAL RUN DONE AND CHECKED THE LT SPEEDS IN DRIVE AND PROGRAM.
OC-19A	PPM DONE ON MOTOR AND FIELD DEVICES
WOBR-L and T	LT PROGRAMMING CHECKING FOR MOTOR HEATERS AND PTC FOR EACH INDIVIDUAL MOTORS
LBDS-2	HOUSE KEEPING DONE IN FIRST FLOOR
MISC	OC-19A,25A,29A,31A,33A,36A,37A PJB INSPECTION AND MAINTENANCE DONE.