



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|------------------------------|-----------------------------|----------------------------------|----------------------------------|---------|
| 1 | OHP | co-25 | tripped on olr | RESET DONE | 02:00:00 22:55:00 23:20:00 | 02:10:00 23:00:00 23:30:00 | |
| 2 | OHP | BRC ON CO-30 | BC ZSS NOT IN PLACE | KEPT IN PLACE | 01:45:00 | 02:00:00 | |
| 3 | OHP | BRC ON CO-30 | BC OLR ACTED | RESET DONE | 04:36:00 | 04:45:00 | |
| 4 | OHP | BRC ON CO 8A | ACB TRIPPED | RELEASED | 04:00:00 | 04:15:00 | |
| 5 | OHP | CO-26 | OLR ACTED | RESET | 04:10:00 | 04:15:00 | |
| 6 | OHP | BRC ON CO-34 | LT NOT WORKING OT ACTED PCRD | RELEASED ... GUIDE ADJUSTED | 23:10:00 | 23:25:00 | |
| 7 | CHP | CC-47 | FAIL TO START | CONTROL RECYCLE AND TESTED | 23:20:00 | 23:33:00 | |
| 8 | CHP | CC-104 SCR -9 | LT NOT WORKING PCRD OT ACTED | RELEASED | 23:30:00 | 23:45:00 | |
| 9 | CHP | CC-39 S-1 | LT NOT WORKING DRIVE TRIPPED | RESET | 03:26:00 | 03:40:00 | |
| 10 | CHP | CC-51 | TRIPPED ON MPD | RESET | 00:20:00 00:50:00 | 00:25:00 00:55:00 | |
| 11 | CHP | CC-55 | TRIPPED ON OLR | RESET DONE | 00:30:00 | 00:40:00 | |
| 12 | CHP | CC-58 | TRIPPED ON OLR 3 TIMES | RESET DONE | 00:40:00 | 01:05:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---------------------------|------------|----------|----------|---|
| 13 | IOSA | oc-27a | MOTOR PROTECTION TRIPPING | RESET DONE | 22:30:00 | 06:00:00 | DECK SHEETS FULL JAM INFORMED OPERATION (NO ELECTRICAL PROBLEM) |