



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/05/2025

Area: IOSA

| Equipment | Job |
|-----------|--|
| OC-3A | |
| UPS | ALL THE POWER AND INTERNAL CABLES CONNECTED. |
| OC-7A | MOTOR PROTECTION RELAY PARAMATRIZATION DONE AND CHECKED THE FUNCTION . IR VALUE CHECKED FOR CABLE & MOTOR. |