



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/02/2026

Area: WT

Equipment	Job
CP 3 jobs	Control desk side wiring done
CP 3 jobs	Antenna pipe and Antenna fixed ,ether net cable crimping connection done
OT 3	M2 motor found burnt,replaced and testing done
CP 1 and 4	After rake maintenance done
OP 1,2,3 and 6	After rake maintenance done