



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/01/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on Co 22	right BC not running,gear box problem	informed mechanical	07:15:00	07:30:00	
2	OHP	wobr on co 26	LT not taking place,m1 olr acted	reset	08:15:00	08:30:00	
3	OHP	co 50	OLR acted	reset	09:45:00	09:55:00	
4	OHP	CO 7	PC acted,earth fault in pc,fuse TB blown	pc bypassed	12:10:00	12:25:00	informed General shift
5	CHP	CC 51	mpd tripped 9 times	reset	07:00:00	07:10:00	
6	CHP	CC 117	olr acted	reset	07:05:00	07:15:00	
7	CHP	CC 51	OLR acted	reset	09:10:00	09:15:00	
8	CHP	CC 31 scr4	slew not working,	fault reset done in operator cabin	08:00:00	08:05:00	
9	CHP	CC 31 SCR4	b/w not working,retuen filter bit missing	return filter bypassed in program,informed mechanical	08:20:00	08:40:00	
10	CHP	C 32	B/C not working,MPD tripped	reset	08:45:00	09:00:00	