



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-58	Reported tripped	MPCB tripped due to overload on belt.(2 times).Reset done	02:00:00 23:00:00	02:12:00 23:05:00	
2	OHP	BRC on CO-28	B/C not running	OLR acted.Reset done(2times)	00:40:00	01:00:00	
3	OHP	CO-29	Reported tripped	OLR acted.Reset done(4times)	00:00:00 01:00:00 04:10:00 05:40:00	00:10:00 01:00:00 04:20:00 05:45:00	
4	CHP	CC-54	Reported tripped	OLR acted.Reset done	00:45:00	00:55:00	
5	CHP	CC-51	Reported tripped	Feeding conveyor stopped(7 times).	22:55:00	01:45:00	
6	CHP	CC-114	Reported tripped	OLR acted.Reset done	01:30:00	01:40:00	
7	CHP	CC-36 SCR-1	Reported slew not taking place	SLew motor side jamming.	23:20:00	23:40:00	Informed to operation.
8	CHP	CC-39 SCR-7	Reported LT not working	Checked and found to be working fine	23:30:00	23:35:00	Wrong Complaint
9	CHP	CC-34 SCR-2	Reported Luffing not taking place	Operator problem.Not able to identify buttons.Not an electrical problem	00:40:00	01:00:00	Informed to operation
10	CHP	CC-38 SCR-6	LT not taking place	Drive tripped.Reset done	01:20:00	01:35:00	
11	CHP	CC-39 SCR-7	LT not working	Checked and found track jamming	02:40:00	02:45:00	Informed to operation
12	CHP	CC-104 SCR-9	Reported luffing not taking place	checked and found MPCB tripped.made on	03:50:00	04:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/08/2025

Shift: C

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-39 SCR-7	Slew and LT not taking place	Slew right LS bypassed due to jamming. LT OT acted and M-2,6 tripped. OT released and MPCB made on	01:05:00	01:30:00	PCRD drum arrested. Informed to mechanical.
14	WT	AF-3	Reported not running in local mode	Checked and found wire cam out of selector switch. Wire reconnected and tested okay	03:00:00 22:30:00	03:15:00 22:40:00	