



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/04/2025

Area: IOSA

Equipment	Job
NEW BATTERY CHARGER	POWER CABLE LAYED AND POWERED NEW BATTERY CHARGER. MADE ON AND CHECKED OUTPUT LOAD VOLTAGES.
OC-19A	LIGHTING DEFECTS RECTIFIED IN OC-19A TUNNEL. INSPECTION ALSO DONE FOR OC-19A CONVEYOR.
	Meggered and trial run done for spare motor at OJH-12A junction house.

160 kw & 30 kw motors