



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/06/2025

Area: OHP

Equipment	Job
JH-2	LDB and CJB maintenance done
CO-10A,RCO-6A,RSCO-1A	PPM done
CO-36,37,47,48,VS-5,2	Running inspection done
CO-61,64,65	Motor and panel PPM side
BRC on Repair Bay	B/C and CT trail run taken after mechanical work
BRC on CO-34	PCRD unwinding and rewinding done
WOBR on CO-26	PPM done
co-6 pullchord	kept in circuit after resetting the switch in slope area.