



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/02/2026

Area: OHP

Equipment	Job
co-33m,33s brc-3 on co-33m	motor and panel side ppm is done
co-26 spare	coupling is removed and sent for overhauling. another spare is found, trail run taken, coupling fixed and shifted to co-26 head end area.
wobr-1 on co-29	bucket wheel motor replaced ; failed motor coupling is removed and sent to ers. sapre 37kw motor shifted from lc7 to hvmcc-1, coupling is fixed and kept ready.
om 10 to om-24 control supply	cable for io rack control supply is traced, checked and charged. to be connected at om24 io rack.
co-3b; co-66,69	motor and panel side ppm is done.
co-8 pullchord	checked and kept in circuit.
co-3a	spare core from brs point to io rack is identified for mechanical brs and is brought to io,, to be programmed in circuit.
co-12a h/e hoist	ppm is done
co-10a,rco-6a,rsco-1a, vf-1a,2a, bf-3a,4a,5a ; rsco-2a,rbf-1a,2a,3a	motor side ppm is done
co-11a gallery	lighting and sockets supply separation is under process.
rsco-1a spare motor	received from ers at lc7