



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/08/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset	13:35:00	13:40:00	
2	OHP	co 20,co 28,co 29	power tripped in LBDS5,two no of fuse blown in i/c of co 20	in LBDS power made On,co 20 power made off in isolator and earthed	13:00:00	14:00:00	co 28 clearance given,co 20, 29 to be checked
3	OHP	CO 14 B	olr acted	reset	09:50:00	09:55:00	
4	OHP	CO 11 (c)	mpcb tripped	made it on	13:35:00	13:45:00	
5	OHP	TT 4	position bit bypass	in local cjb	11:45:00	11:50:00	
6	CHP	cc 51	mpd trips in digital overload ,feeding conveyor stopped	reset	09:46:00	09:48:00	
7	CHP	CC 104 scr 9	bw pump not working,emergency stop operated near b/w	emergency released,analog o/p card checked plc power recycle than frequency reference came for slew ,b/w,lt	09:10:00	11:00:00	
8	CHP	CC 35 SCR1	LT not taking place	track jammed informed operation	12:10:00	12:35:00	
9	WT	OP3	breaker tripped	made it on	09:30:00	09:40:00	
10	WT	CP3	pusher no power,acb tripped	made it on	13:10:00	13:20:00	