



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/05/2025

Area: IOSA

Equipment	Job
OC-27A	LIGHTING DEFECTS RECTIFIED AT HEADEND
BRC	BRIDGE CONVEYOR BRAKE PANEL NOT WORKING, GOT RUSTED AND DAMAGED. REMOVED AND SHIFTED TO SHED FOR RECTIFICATION
OC-5A	MOTOR PPM DONE.
OC-37A	LIGHTING DEFECTS RECTIFIED AND LIGHTING ARRANGED.
BRC	POWER CABLE DRESSING DONE.