



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/08/2025

Incharge(s): Lal Singh

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|---|----------|----------|---------|
| 1 | OHP | CO-35 | OVER LOAD ACTED | RESET DONE | 08:35:00 | 08:40:00 | |
| 2 | OHP | CO-34 BRC | NO DRIVES WORKING | ACB TRIPPED... MADE ON | 09:45:00 | 10:00:00 | |
| 3 | OHP | CO-6A WBR | LT NOT WORKING | MAIN IS IN OFF CONDITION MADE ON | 11:55:00 | 12:10:00 | |
| 4 | OHP | CO-26 WOBR | SLEW NOT WORKING | DRIVE TRIPPED RESET DONE | 12:20:00 | 12:40:00 | |
| 5 | OHP | CO-31 BRC | CHUT SENSOR ACTING BYPASS REQ FROM OPERATION | BYPASSED IT IS ACTING BECOUSE OF MATERIAL TOUCHING TO PROB | 10:50:00 | 11:10:00 | |
| 6 | OHP | CO-15 | PULL CORD KEPT IN CKT | DONE | 12:00:00 | 12:10:00 | |
| 7 | CHP | cc-105 scr-7 | HT CABLE PROBLEM | OLD JOINT FAILED... ISOLATOR MADE OFF .. INFORMED TO G SHIFT | 06:15:00 | 06:30:00 | |
| 8 | CHP | CC-38 S-1 | PCRD GEARBOX PROBLEM | DRUM ARRESTED AND INFORMED TO MECH AND OPERATION | 12:45:00 | 13:15:00 | |
| 9 | CHP | CC-27A TT | TT POSITION ON CC-39 NOT COMING | SENSOR CLEANING DONE THEN OK | 07:30:00 | 07:35:00 | |
| 10 | CHP | CC-114 | TRIPPED ON OLR | RESET DONE | 13:40:00 | 13:45:00 | |