



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 84	OLR acted	reset	21:00:00	21:10:00	
2	OHP	CO 78	ZSS acted,probe and cage problem	probe and cage replaced	19:40:00	20:30:00	
3	CHP	CC 104 SCR 9	BC not running, EB03 fault in PLC	communication establised and program checked found material selection problem	19:00:00	21:30:00	
4	CHP	CC 32 R1	BC not running,zss cage stucked	cage made free	19:30:00	19:45:00	
5	CHP	CC 38 SCr 6	bc not running,zss cage stucked	cage made free	21:00:00	21:15:00	
6	CHP	CC 36 S2	LT not working,drive tripped	reset	19:10:00	19:20:00	
7	CHP	CC 36 s2	LT not working,MPCB tripped	made it on	14:50:00	15:10:00	