



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/06/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	POWER CABLE TERMINATION DONE AND TRIAL RUN TAKEN AFTER HT CABLE BOOTING AND LUGGING BY DNW TEAM.
BLENDER RECLAIMER	BLENDER TO YARD CONVEYOR ZSS CAGE GOT STRUCK. REPLACED WITH SPARE.
OC-31A	PPM DONE ON MOTOR and FIELD DEVICES