



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/08/2025

Shift: B

Incharge(s): Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|--|----------------------|----------------------|---------|
| 1 | OHP | CO 11 | Belt drive mpcb tripped | reset done | 17:10:00 | 17:20:00 | |
| 2 | OHP | TT 2 | Incoming 4 pole 100A MCB damaged | MCB replaced | 15:20:00 | 15:45:00 | |
| 3 | OHP | CO 11 | OLR acted | reset done | 16:55:00 | 17:05:00 | |
| 4 | OHP | CO 29 | OLR acted | reset done | 16:05:00 18:20:00 | 16:10:00 18:30:00 | |
| 5 | OHP | CO 35 | OLR acted (2 times) | reset done | 19:25:00 | 20:00:00 | |
| 6 | OHP | CO 26 | OLR acted | reset done | 19:45:00 | 19:50:00 | |
| 7 | OHP | CO 70 | BRS not getting reset due to belt pieces | belt pieces removed | 14:45:00 | 15:10:00 | |
| 8 | OHP | WOBR on CO 26 | BC not rotating due to zss acted | checked, belt slipping. Informed to mechanical | 20:30:00 | 20:45:00 | |
| 9 | CHP | CC 54 | OLR acted (5 times) | reset done | 19:05:00 | 21:30:00 | |
| 10 | CHP | CC 29 | Flap gate tripped | reset | 14:30:00 | 14:40:00 | |
| 11 | CHP | CC 26A | Flap gate tripped | reset | 14:55:00 | 15:10:00 | |
| 12 | CHP | CC 26 TT | Not moving , tripped | reset done | 15:15:00 | 15:20:00 | |
| 13 | CHP | CC 14 | OLR acted | reset done | 15:20:00 | 15:30:00 | |
| 14 | CHP | CC 34 , SCR 2 | LT not working | pcrd cable OT acted , released | 16:00:00 | 16:20:00 | |
| 15 | CHP | CC 39 , S 1 | LT not working | Drive tripped , reset | 16:10:00 | 16:25:00 | |
| 16 | CHP | CC 39 , S 1 | LT problem due to pcrd cable fell down | cable winded properly | 17:40:00 | 17:50:00 | |
| 17 | CHP | CC 38 , SCR 6 | BC frequently stopping due to signal missing | LT done then okay. Also yard ZSS problem due to cage . Cage replaced . | 20:20:00 | 20:50:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/08/2025

Incharge(s): Arnab Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|---|----------|----------|---------|
| 18 | CHP | CC 112, S 3 | LT not working due to pcrd motor mpcb tripped | mpcb on , then ok | 21:40:00 | 21:50:00 | |
| 19 | WT | OP 7 | No movement bcz of MCCB tripped (box no -53) | made on | 19:00:00 | 19:15:00 | |
| 20 | WT | CP 3 | No movement due to D2 motor burnt and D3 motor bed got down and tyre damaged | D2 motor connection removed and for D3 motor informed to mechanical | 14:00:00 | 15:00:00 | |
| 21 | WT | CP 3 | Not moving bcz of D3 OLR acted | reset done | 20:40:00 | 20:55:00 | |
| 22 | WT | SCO 1A | Belt drive OLR acted | reset done | 17:10:00 | 17:15:00 | |
| 23 | IOSA | TBS on OC13A | LT end limit acted | reset done | 19:00:00 | 19:15:00 | |