



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Co 25	olr acted	reset	16:00:00	16:30:00	
2	OHP	Co 38A	ZSS probe wire got cut	probe replaced	17:50:00	18:00:00	
3	CHP	CC 105 SCR10	signal missing	LT done than ok	15:30:00	15:40:00	
4	CHP	CC 34 SCR1	LT not working,track jammed	informed operation	21:20:00	21:30:00	
5	CHP	CC 51	mpd tripped	reset	21:15:00	21:20:00	
6	CHP	CC 52	mpd tripped	reset	15:00:00	21:00:00	3 times
7	CHP	CC 131	motor tripped 3 times	reset	15:00:00	18:00:00	
8	CHP	cc 53	mpcb tripped due to overload	made it on	21:30:00	21:40:00	
9	WT	OT 2	d2 tripped pgf1 fault	reset	15:00:00	21:00:00	
10	WT	OC 1A	zss acted,probe problem	probe and module replaced	16:00:00	16:15:00	