



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/06/2025

Area: CHP

Equipment	Job
Coal complex,LC 17	Rooms cleaning done
SCR 10	5 nos tube fixtures replaced in MCC room
SCR 4	PCRD rev command relay replaced and trial run was taken
SCR 1	Boom position sensor kept in ckt
CC 201 to 206	PPM was done