



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 25	SLEW NOT TAKING PLACE M2 OLR ACTED	RESET	14:50:00	15:05:00	
2	OHP	TBS ON CO 20	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASEAD	15:30:00	16:00:00	
3	OHP	BRC ON CO 33M	CT NOT TAKING PLACE OPERATOR CABIN SIDE LIMIT ACTED	RELEASED	16:45:00	17:00:00	
4	OHP	BRC ON CO 8A	B/W 1 STOPPING ON ZS	ZS PROBE GAP ADJUSTED THAN OK	17:45:00	18:00:00	
5	OHP	CO 26	OLR ACTED (2TIMES)	RESET	18:00:00	19:45:00	
6	OHP	CO 29	OLR ACTED (2TIMES)	RESET	18:40:00	20:15:00	
7	OHP	TBS ON CO20	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	20:30:00	20:45:00	
8	OHP	VS1A	olr acted	reset	21:35:00	21:45:00	
9	CHP	cc 201	pc acted	released	14:30:00	14:40:00	
10	CHP	CC 104 SCR 9	slew not working,olr acted	reset	16:40:00	16:45:00	
11	CHP	CC 39 SCR 7	LT not working,OT acted	released it than healthy	16:55:00	17:00:00	
12	CHP	CC 32 SCR 5	B/C not running,cjs acted due to jamming	informed operation	18:00:00	18:10:00	
13	CHP	CC 36 S1	signal missing complaint, wrong complaint	boom conveyor and yard conveyor running	18:10:00	18:20:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 39 SCR 7	b/c not running, trips in olr	reset	18:26:00	18:40:00	
15	CHP	CC 40 scr 6	slew not working, pup not made on	pump made on	19:40:00	19:50:00	operator problem
16	CHP	CC 105 SCR 10	luff not working	wrong complaint	20:30:00	20:45:00	
17	CHP	CC 54	OLR ACTED(2TIMES)	RESET	20:35:00	20:55:00	
18	CHP	CC 33 SCR4	LT not working	wrong complaint	19:55:00	20:10:00	
19	WT	OC 1A	STOPPING ON ZS DUO TO MATERIAL JAMMING	IN FORMED TO OPERATION	18:55:00	19:30:00	