



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/11/2025

Area: IOSA

| Equipment | Job |
|-----------------|---|
| OC-15A | PPM DONE ON MOTOR . |
| OC-7A | CJB DOOR HAS COME OUT. DOOR FIXED BACK AFTER FIXING HINGES. |
| OC-36A | DEFECTIVE LIGHT FITTINGS REMOVED AND LIGHT FITTING PROVIDED IN CONVEYOR GALLERY. |
| OTT-1A | MATERIAL CLEARED FROM COMPOSITE CABLE AT OC-11A GALLERY. CABLE ROUTED THROUGH CABLE TRAY. |
| OC-9A | ZSS CAGE AND MODULE FIXED. TAKEN INTO LINE AND FEEDBACK CHECKED. |
| THRUSTER BRAKES | REMOVED FROM SCR-9 AND SHIFTED LC-2 SHED FOR TESTING. |