



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/06/2025

Area: OHP

| Equipment | Job |
|---|---|
| RSCO-10A | ZSS probe adjustment angle provided and tested okay |
| BRC-5 ON CO-33M | LT-2 Drive installation done.Parameterization done and LT tested okay |
| rsco-6a level | illumination is improved. |
| vs-1a to vs-5a | hoists ppm is done |
| vf-1a,vf-2a,bf-3a,4a,5a, vs-1a,2a,3a,4a,5a; bf-1a,2a,7a,8a,9a | cjd ppm is done |
| brc-4 on co-34 | festoon cable chain was damaged, guide rollers adjusted, clamping ,dressing of cables is done |
| tbs- on co-21 | safety devices ppm is done |
| TBS-3 ON CO-7A | ppm is done |