



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-26	Reported slewing not taking place	Drive tripped.Reset done	08:55:00	09:10:00	
2	OHP	BRC on CO-34	Reported LT not taking place	M-1 OLR acted.Reset done	12:30:00	12:45:00	LT healthy wire found loose at PLC TB.Tig htened
3	CHP	CC-51	MPD tripped	Feeding conveyor stopped.Reset done(3 times)	11:26:00	13:20:00	
4	CHP	CC-132	Reported tripped	OLR acted.Reset done	07:55:00	08:00:00	
5	CHP	CC-117	Reported tripped	OLR acted.Reset done	09:59:00	10:50:00	
6	CHP	SCR-7 on CC-37	Reported slewing not taking place	Spider brake fail alarm acted.Reset done	13:30:00	13:45:00	
7	WT	OT-2	Reported tripped	Drive-1 tripped on PGEF-1 fault.Reset done(2 times)	09:05:00	09:10:00	