



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	B/C not running,zss acted,cage stucked due to stone	cage made free	23:30:00	23:50:00	
2	OHP	WOBR CO 25	B/C not running,C/S acted due to jamming	informed operation	00:00:00	00:10:00	
3	OHP	BRC on CO 31	b/C not running,olr acted	reset	03:15:00	03:30:00	
4	OHP	WOBR on CO 6A	LT not taking place,OT acted	OT released	03:15:00	03:30:00	
5	OHP	CO 35	olr acted	reset	00:00:00	00:10:00	
6	OHP	RSCO 6A	olr acted	reset it done	05:30:00	05:45:00	
7	OHP	CC 104 SCR 9	slew not working,slew pump mpr tripped in e/f	reset	02:00:00	02:10:00	
8	CHP	CC 33	OLr acted	reset	22:30:00	22:35:00	
9	CHP	CC 201	OLR acted	reset	22:35:00	22:40:00	
10	CHP	CC 40 SCR 6	Slew not working ,30 limit acted	informed operation	02:00:00	02:05:00	
11	CHP	CC 104	conveyor not running even healthy,remote manual operation mode not selected in CCR	told operator to select in manual mode not route mode	01:15:00	02:00:00	
12	CHP	cc 117	motor trip in OLR	reset	22:40:00	22:50:00	
13	CHP	CC 54	olr acted	reset it done	04:04:00	04:10:00	3 times