



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 05/12/2025

Area: OHP

Equipment	Job
cr-1a,2a,3a,	motor and panel side ppm is done. cr-3a VIBRATION sensor fixing plate is damaged, replaced it. feeder ready for operation indication lamp is replaced in cr-2a.
bf-2a zss	probe fixing stand replaced.
wobr-2 on co-25 ; tbs-6 on co-7a	ppm is done.
co-84 take up area ; 47 gallery ; vs-1a level ; vf-1a leve ; co-11a belt scale.	lighting is improved.
pcrd cables healthiness inspection	transfer car ; tbs-1 on co-22 ; brc-1 on co-30 proper insulation is provided.
brc-1 on co-30	slip ring and ht coupler maintenance is done. festoon cable maintenance is done. CT speed section/adjustment is provided in operator cabin for 3 steps, (Low/medium/High)
1-141LC4 to LC6	profibus cable fault is found, further checks needs to be done.
jh 14,bpc-1,bpc-2 h/e hoists	ppm is done
co-65,66,67,8a,28 belt scales	ppm is done
co-59 gallery ; co-67 head end area	lighting is improved.