



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/06/2025

Area: IOSA

Equipment	Job
OC-23A	PPM DONE ON MOTOR. IR VALUE CHECKED AND RECORDED.
LBDS-2 RIO	RACK - B STOPPED COMMUNICATING. POWER TO RACK RECYCLED AND GIVEN CLEARANCE.
WOBR-FLS	PPM DONE ON ALL MOTORS. IR VALUES CHECKED AND RECORDED.
OC-27A	PPM DONE ON ZONE-2 and 3 FILED DEVICES. FIELD DEVICES FEEDBACK CHECKED.
OC-21A	PPM DONE ON MOTOR. IR VALUES TAKEN.