



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/01/2026

Incharge(s): Lal Singh, Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-28 BRC	PUMP NOT RUNNING ... ACC-2 ALARM	INFORMED MECH FOR NITROGEN FILLING NO ELECTRICAL PROBLEM	03:30:00	03:45:00	
2	OHP	CO-32 BRC	HYD PUMP NOT RUNNING ... OIL LEVEL LOW	INFORMED MECH	23:00:00	23:15:00	
3	OHP	CO-32 BRC	BW-1 NOT RUNNING STUCK	MADE FREE BY REV ROTATING	01:15:00	01:30:00	
4	OHP	CO-85	TRIPPED ON OLR	RESET DONE	00:05:00 23:02:00	00:20:00 23:09:00	
5	CHP	cc-47	FAIL TO START	POWER AND CONTROL RECYCLE THEN TESTED OK	23:15:00	23:30:00	
6	CHP	CC-104 SCR-9	PLC COMMUNICATION FAILED EB03 FAULT	PLC POWER RECYCLED	03:55:00	04:25:00	
7	CHP	CC-18	STOPPING ON ZSS	CAGE STUCK ... MADE FREE	05:25:00	05:35:00	
8	CHP	CC-114	TRIPPED ON OLR	RESET DONE	01:40:00 05:40:00	01:50:00 05:50:00	
9	WT	OT-2	TRIPPED ON PGF-1 FAULT	RESET DONE	01:50:00 03:15:00 22:15:00	01:55:00 03:20:00 22:20:00	
10	WT	OT-1	WAGON OVER TRAVELED AND TIPPLER AT 20 DEGREE	SENSOR AND REV LIMIT BYPASSED TO BRING TIPPLER AT 0 DEGREE THEN KEPT IN CKT	04:00:00	04:10:00	