



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/05/2025

Area: CHP

| Equipment                               | Job   |
|---|---|
| CC 102 TT                               | Cable winding done properly   |
| SCR 4                                   | Main contactor bypass removed and tested from operator cabin                    |
| SCR 8                                   | Air Blast cooler PLC wiring done and kept in ckt, Slew 30 degree limits checked |
| CC 40,104,105,111,112                   | Motor vibration values checked  |
| REC 3                                   | LT motors and PCRD motor removed and shifted to mixture building                |
| CC<br>107,207,208,209,210,211,212,21,25 | PPM was done  |
| SCR 1,S 1                               | Yard machine interchanging done   |