



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 20/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 10 A	carriage drive olr acted	reset	23:11:00	23:20:00	
2	OHP	CO 34	olr acted	reset	23:55:00	00:05:00	
3	OHP	CO 35	OLR acted	reset	00:35:00	00:45:00	
4	OHP	VS 2	olr acted	reset	05:10:00	05:15:00	
5	OHP	TIS on CO6	Feed back missing inbetween	TIS power is in off condition bypass condion.... power made on then ok	00:15:00	00:40:00	
6	CHP	CC223	motor not healthy found CJS acted due to chute jamming	informed to operation	22:40:00	22:50:00	
7	CHP	SCR6 on Cc38	TUL bypassed as per opertional request	Bypassed	23:45:00	23:45:00	
8	CHP	SCR1 on CC35	*Luffing not working due to motor over load *LT not working found 2 and 5 and 6 MPCB trip	*Reset done *MPCB made on then ok	23:50:00	00:00:00	
9	CHP	SCR4 on CC33	LT not working found PCRD over tension acted	OT released then ok	00:00:00	00:10:00	
10	CHP	SCR3 on CC40	LT and slewing not working found mains not on	Mains made on then LT and slew ok	02:40:00	02:50:00	
11	CHP	SCR9 on CC104	Slew not working found power MCCB trip	MCCB made on then ok	02:50:00	03:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC51	MPD trip on over load 5 times due to over material on belt	Informed to operation and reset done	23:15:00	23:20:00	12.05am to 12.10am:02.30am to 02.35am:02.45am to 02.50am:03.30am to 03.35am
13	IOSA	OC13a	Left middle belts way acted condtion	Bypassed after stream stops is to be checked infomed to Z shift	03:45:00	03:45:00	