



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/05/2025

Area: OHP

Equipment	Job
co-4a	pullchord switch is acted, reset done and restored in circuit.