



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/11/2025

Area: WT

Equipment	Job
MIS	Damaged coupling of pusher motor removed and fixed spare coupling
LC 2A	Antenna with modem, antenna cable ,PLC replaced and PLC replaced in LC 1 also
OP 1	Trolley line inspection done, parking area section found un even, rectified
OP 2	After rake maintenance done