



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/08/2025

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-2	Reported not moving	cable got short at old joint at pendulum entry due to material build up at conveyor side.Cable rejoint done and tested okay	12:36:00	13:15:00	
2	OHP	TT-1	Position indication not coming at CO-22 chute	Bypassed at I/O due to sensor problem	08:20:00	08:35:00	Sensor to be checked/ changed and to be kept in line
3	OHP	TT-2	Position on CO-21 not coming	Bypassed at I/O rack for rake delay and then again kept in line after checking and clearance	10:40:00	10:50:00	
4	OHP	CO-58(B/D)	Reported Tripped	MPCB tripped due to jamming.Reset done	08:00:00	08:10:00	Informed to operation
5	OHP	CO-67	Reported tripped	OLR acted.Reset done	08:20:00	08:30:00	
6	OHP	RSCO-1A(C/D)	Reported not moving	OLR acted due to track jamming.Reset done	10:30:00	10:40:00	Informed to operation
7	OHP	WOBR on CO-26	Reported B/C not moving	Checked and found B/C stuck with material.Luffing done and made free and tested okay	08:30:00	08:45:00	
8	OHP	TBS ON CO-19	Reported LBC stopping	ZSS cage stuck with stone. Stone removed and tested okay	08:30:00	08:45:00	
9	OHP	WOBR on CO-26	PCRD not rotating	PCRD gearbox output shaft not rotating because of chain stuck,.Chain made free by mechanical	13:30:00	14:00:00	Chain is loose.TO be adjusted.



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/08/2025

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC-29 TT	Position indication showing for both CC-32 and CC-111	wire removed at I/O rack for CC-111.	10:15:00	10:25:00	to be checked
11	CHP	CC-26 TT	Reported LT not taking place	MPCB tripped.Made on	12:15:00	12:25:00	
12	CHP	CC-39 SCR-7	Reported LT not taking place	Checked and found track jamming	08:35:00	08:45:00	Informed to operation
13	CHP	CC-201	Reported tripped	OLR acted.Reset done	08:05:00	08:15:00	
14	CHP	CC-32 SCR-5	Reported signal missing	Antenna cleaning done and ethernet cable checking done from plc to wireless modem and ZSS interlock cage kept in line and given clearance	09:38:00	10:15:00	
15	CHP	CC-112 SCR-8	B/C not working	MPR tripped on earth fault.Checked and reset done and tested okay	10:40:00 12:20:00	10:50:00 12:35:00	
16	CHP	CC-105 SCR-10	Reported yard running signal missing	ZSS interlock cage stuck. changed and tested okay	13:35:00	13:45:00	
17	CHP	CC-51	Feeding conveyor CC-31 Stopping	Due to MPD acted for CC-51(3times)	08:55:00 09:20:00 09:45:00	09:00:00 09:30:00 09:50:00	
18	CHP	CC-54	Reported Tripped	OLR acted.Reset done(4times)	10:30:00 10:55:00 13:50:00 14:00:00	10:35:00 11:00:00 13:52:00 14:03:00	