



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/06/2025

Area: CHP

| Equipment | Job |
|-----------------------|--|
| STKR-1 | micrologix 1100 provided in drive panel removed |
| SCR-1 | Boom position circuit checked and bypass removed |
| SCR-10,CC-126 GALLERY | lighting circuit rectification done |
| SCR-10 | motors ppm done |
| SCR-10 | micrologix-1400 replaced, communication checked and found ok |
| CC-41,47 | Running inspection done |
| RG-2 | minus level chute vibrator fixed and kept in circuit |
| VS-1,VF-1 | panel and motor ppm done |
| RG-1 | HT motor ppm done |