



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on Co5A	LT not stopping,wrong complaint	checked both LT in FWd and REv for 20 minutes nothing found,all ok	15:55:00	16:10:00	
2	OHP	WOBR ON co 25	LT not stopping,brake problem mechanical	informed mechanical,mechanical adjusted brake	21:05:00	21:20:00	
3	CHP	CC 51	MPD acted	reset	16:30:00	16:35:00	6 times
4	CHP	CC 39 STK2	LT not working,PCRD OT acted,loop formed in PCRD cable	unwinding ,winding done properly	15:00:00	15:10:00	
5	CHP	CC 201	OLr acted	reset	17:45:00	17:55:00	