



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/06/2025

Area: CHP

Equipment	Job
CC 43/44 tunnel	Air blower fan motor freed and kept running
CC 41,45,125 tunnel	9 nos LED lamp fixtures replaced ,ckt problems rectified and improved lighting
SCR 1,SCR 7	30* and slew limits ckt problems rectified and kept in ckt tested
CC 25	Electronic OLR replaced and tested
CC 43	PPM was done
CC 41,42 tunnel	Air blower found burnt