



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/10/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-33M	STOPPING ON ZSS FOUND ZSS PROBE DAMAGED	ZSS PROBE REPLACED THAN OK	17:00:00	17:20:00	
2	OHP	CO-29	OLR ACTED	RESET DONE	16:10:00	16:20:00	
3	OHP	CO-26	TRIPPED ON OLR	RESET DONE	16:30:00	16:35:00	
4	OHP	CO-58	TRIPPED ON OLR(2TIMES)	RESET DONE	16:45:00 18:10:00	16:55:00 18:20:00	
5	CHP	CC-54	TRIPPED ON OLR (8TIMES)	RESET DONE	15:30:00	21:10:00	
6	CHP	CC-203	TRIPPED ON OLR	RESET DONE	15:25:00	15:35:00	
7	CHP	CC-31 SCR-4	REPORTED LUFF DOWN NOT WORKING LIMIT ACTED	RELEASED THAN OK	16:30:00	16:45:00	
8	CHP	CC-112 SCR-8	SLEW NOT WORKING LIMIT ACTED LIMIT CAM MALFUNCTION	LIMIT BYPASSED	15:30:00	15:45:00	