



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/07/2025

Area: WT

| Equipment | Job |
|------------|---|
| OP 10 | Creepers along trolley line removed bottom side from col no 15 to 3 |
| OC 1A | Area lighting problem rectified ,200W and 35W LEDs replaced |
| OP 1 and 4 | after rake maintenance done |