



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 25/11/2025

Area: IOSA

Equipment	Job
OC-21A	ADDITIONAL LIGHTING PROVIDED FOR BELT PI JOB.
MANUAL UNLOADING YARD	KEPT LIGHTING CIRCUIT IN MANUAL AND CHECKED THE LIGHTING IN MANUAL UN-LOADING YARD.
OC-21A	LIGHTING INSPECTION DONE AND DEFECTS RECORDED.
MISC	CABLE IN ELECTRICAL SHED IS ARRANGED PROPERLY.
OJH-11A	ONE LED LIGHT FITTING PROVIDED AT OJH-11A JUNCTION HOUSE
1-14LBDS#2	LED LIGHT PROVIDED NEAR DOOR ENTRANCE ON LBDS BUILDING.
WOBR-FLS	MAINTENANCE DONE ON SLIPRING ASSEMBLY AND HT TRANSFORMER HT AND LT TERMINATIONS.
BLENDER RECLAIMER	MAINTENANCE DONE ON SLIPRING ASSEMBLY, HT TRANSFORMER HT and LT TERMINALS.
TBS	MAINTENANCE DONE ON SLIP RING ASSEMBLY, HT TRANSFORMER CONNECTIONS
OC-23A	PPM DONE ON HT BREAKER. CHECKED THE OPERATION IN LOCAL and BREAKER ISOLATED