



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/01/2026

Area: OHP

Equipment	Job
brc-4 on co-28	oil level switch and suction line switch, checked and restored in circuit. nitrogen is filled and restored acc2 also in circuit.