



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/02/2026

Area: IOSA

Equipment	Job
IOSA-PLC	HARDWARE CONFIGURATION BACKUP TAKEN IN LAPTOP FOR OM-4, 1-142LC2 AND 1-142LC-3 RIO.
IOSA_ CPU B	GBC CARD REPLACED IN CPU-B .
1-28HVMCC - 5	BUS COUPLER MODULE AND PANEL DEFECT RECTIFICATION IN PROGRESS.
OC-2A	BRS UNIT MAINTENANCE DONE. FEEDBACK AND INTERLOCK CHECKING DONE.