



वी.एस.पी.
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/11/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO16	olr acted	reset	04:15:00	04:20:00	
2	OHP	CO 26	olr acted	reset	03:30:00	03:40:00	
3	OHP	WOBR on Co 6A	luffing not working,checked all healthy	mechanical complain	22:30:00	22:40:00	
4	OHP	CO 21	ZSS probe fixing plate bend	plate replaced	01:40:00	01:50:00	
5	CHP	CC 51	MPD tripped 2 times	reset	03:00:00	04:00:00	
6	CHP	CC 130	stopped in ZSS, cage stucked due to material	material removed	02:30:00	02:40:00	
7	CHP	CC 38 SCR 6	LT not working,OT acted	released	01:50:00	02:10:00	
8	CHP	CC 39 SCR 2	LT not working,OT acted	released	00:45:00	00:59:00	