



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/11/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 21	Lt not working,brake problem	informed mechanical	14:50:00	15:10:00	
2	OHP	BRC on Co 28	LT not working,wrong complaint	informed operation	17:00:00	17:10:00	
3	OHP	WOBR on co 26	slew not working,drive tripped	reset	18:00:00	18:20:00	
4	OHP	CO 29	olr acted	reset	17:35:00	17:45:00	
5	CHP	CC 104 scr9	slew not working,slew aux contact of OL relay problem	aux contact replaced	14:10:00	14:25:00	
6	CHP	CC 125	olr acted	reset	17:35:00	17:45:00	
7	CHP	CC 35 SCR3	LT not working,drive tripped	reset	17:50:00	18:06:00	
8	CHP	CC 34 SCr 1	LT not working,drive tripped	reset	19:10:00	19:30:00	
9	CHP	CC 105	brs acted,operation told not resetting,wrong complaint	BRS easily got reset	20:00:00	20:10:00	
10	CHP	CC 117	motor trips due to overload	reset	19:40:00	20:00:00	
11	IOSA	BRC	LT not working,LT limit switch acted due to rod	rod removed	20:15:00	20:30:00	
12	IOSA	OC 15 A	ZSS acted ,stone stucked in cage	stone removed	20:59:00	21:10:00	