



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	tripped on olr	reset done	00:20:00	00:35:00	
2	OHP	co 14a	brs acted	reset done	04:45:00	05:15:00	
3	OHP	CO87	Over load acted	Reset done	03:20:00	03:30:00	
4	OHP	RSCO6a	Chute vibrator not working found B phase got opened	Rejointed then ok	00:30:00	01:00:00	
5	OHP	CO14a	BRS not working checked reset button strucked with dust	Dust removed PB released then ok	04:50:00	05:15:00	
6	CHP	SCR1 on CC36	Slew motor value zero complaint from B shift motor replaced and trail taken	Given clearance electrically	22:00:00	02:15:00	
7	CHP	SCR3 on CC38	AC and fan not working	Fan working AC compressor not working	00:00:00	00:20:00	
8	CHP	SCR9 on CC104	All drives red found incomer trip	Made on	02:40:00	02:50:00	
9	CHP	CC33	Yard conveyor stopping 3 times found over load inerlock with CC51	Over load reset done in CC51 then CC33 ok	02:00:00	03:00:00	
10	CHP	RG2	Under speed acted found ZSS module problem	ZSS module changing work under progress	05:40:00	06:00:00	